

Portable Appliance Testing (PAT) Record

Tester Name:	David Brown	Equipment Test:	Bunny Bunny Jabba PA system
Address:	Lake Ridge Cottage, Hurn, Christchurch, BH23 6AU	Test Date	March 2026
PAT Certification No:	FE1253-1	Next Test Due	December 2027

Item ID	Appliance	Location	Date of Test	Visual Check	Fuse Rating	Earth Continuity	Insulation Test	Next Test Due	Safe to Use
I1	IEC power lead	Lead Storage	03/2026	Pass	13Amp	Pass	IR > 60 MΩ (DMM)"	02/2027	Yes
I2	IEC power lead	Lead Storage	03/2026	Pass	13Amp	Pass	IR > 60 MΩ (DMM)"	02/2027	Yes
I3	IEC power lead	Lead Storage	03/2026	Pass	13Amp	Pass	IR > 60 MΩ (DMM)"	02/2027	Yes
I4	IEC power lead	Lead Storage	03/2026	Pass	13Amp	Pass	IR > 60 MΩ (DMM)"	02/2027	Yes
I5	IEC power lead	Lead Storage	01/2026	Pass	13Amp	Pass	N/A – 1YR	12/2026	Yes
I6	IEC power lead	Lead Storage	01/2026	Pass	13Amp	Pass	N/A – 1YR	12/2026	Yes
I7	IEC power lead	Lead Storage	01/2026	Pass	13Amp	Pass	N/A – 1YR	12/2026	Yes
I8	IEC power lead	Lead Storage	01/2026	Pass	13Amp	Pass	N/A – 1YR	12/2026	Yes
MX	Mixer Power supply	Music Room	03/2026	Pass	5A	Pass	N/A – 1YR	02/2027	Yes
KB	Keyboard Power Supply	Music Room	03/2026	Pass	5A	Pass	N/A – 1YR	02/2027	Yes
BA	Bass Amp	Music Room	03/2026	Pass	N/A IEC	Pass	IR > 60 MΩ (DMM)"	02/2027	Yes
S1	10" Spkr S250301645976	Music Room	01/2026	Pass	N/A IEC	Pass	N/A – 1YR	12/2026	Yes
S2	10" Spkr S250301648976	Music Room	01/2026	Pass	N/A IEC	Pass	N/A – 1YR	12/2026	Yes
S3	12" Spkr S250600609A2E	Music Room	01/2026	Pass	N/A IEC	Pass	N/A – 1YR	12/2026	Yes
S4	12" Spkr S250600611A2E	Music Room	01/2026	Pass	N/A IEC	Pass	N/A – 1YR	12/2026	Yes
EX1	Extension Lead	Lead Storage	03/2026	Pass	13Amp	Pass	IR > 60 MΩ (DMM)"	02/2027	Yes
EX2	Extension Lead	Lead Storage	03/2026	Pass	13Amp	Pass	IR > 60 MΩ (DMM)"	02/2027	Yes
EX3	Extension Lead	Lead Storage	03/2026	Pass	13Amp	Pass	IR > 60 MΩ (DMM)"	02/2027	Yes
EX4	Extension Lead	Lead Storage	03/2026	Pass	13Amp	Pass	IR > 60 MΩ (DMM)"	02/2027	Yes

I confirm that the above appliances have been inspected and tested in accordance with relevant guidelines and are recorded accurately.

Tester Signature:	<i>D Brown</i>	Date:	26 th March 2026
	David Brown		